

AMENDMENT NO. 2 JUNE 2018
TO
IS 2713 (PARTS 1 TO 3) : 1980 SPECIFICATION FOR
TUBULAR STEEL POLES
FOR OVERHEAD POWER LINES

(Second Revision)

(Page 3, Foreword, clause 0.3) — Substitute the following for the existing clause 0.3:

‘0.3 This standard (Second Revision) was formulated in 1980 in three parts as follows:

- | | |
|--------|--|
| Part 1 | General Requirements |
| Part 2 | Special Requirements for poles made from steel of tensile strength 410 MPa |
| Part 3 | Special Requirements for poles made from steel of tensile strength 540 MPa |

Part 3 of this standard has been deleted in 2018 as the steel of tensile strength 540 MPa is no longer covered in IS 1161 : 2014 ‘Steel tubes for structural purposes — Specification (*fifth revision*)’, which is cross-referred for quality requirements of tubes for making poles.’

(Page 3, Foreword, clause 0.3) — Insert the following new clause at the end:

‘0.4 The standards cross-referred to in this Indian Standard are subject to revision. The latest version of these standards may be referred for the purpose of compliance to the concerned requirements of this standard.’

PART 1 GENERAL REQUIREMENTS

(Second Revision)

(Page 4, clause 1.2) — Substitute the following for the existing clause:

‘1.2 These general requirements apply to tubular steel poles made of steel of minimum tensile strength 410 MPa that is covered in Part 2 of this standard.’

Amendment No. 2 to IS 2713 (Parts 1 to 3) : 1980

**PART 3 SPECIAL REQUIREMENT FOR POLES MADE FROM
STEEL OF TENSILE STRENGTH 540 MPa**

(Second Revision)

(Page 23, Part 3) — Delete the complete Part 3 of this standard.

(CED 07)

Publication Unit, BIS, New Delhi, India